

初野浄水場 流量水質報告書

令和5年4月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7次 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	36,590	2.44	7.43	—	23,510	20,090	1.58	7.49	8.10	0.00	0.00	
2	35,120	2.41	7.43	—	23,140	18,310	1.56	7.49	8.10	0.00	0.00	
3	36,240	2.34	7.40	—	24,270	18,970	1.54	7.47	8.00	0.00	0.00	
4	35,180	2.38	7.44	—	23,110	18,710	1.56	7.51	8.10	0.00	0.00	
5	37,550	2.00	7.45	—	24,240	20,050	1.53	7.51	8.50	0.00	0.00	
6	35,540	1.99	7.43	—	23,170	18,800	1.52	7.48	8.70	0.00	0.00	
7	35,940	2.12	7.42	—	23,370	18,700	1.54	7.45	9.10	0.00	0.00	
8	35,440	2.15	7.40	—	23,480	18,230	1.61	7.45	9.30	0.00	0.00	
9	35,910	2.58	7.42	—	24,150	18,420	1.77	7.48	9.70	0.00	0.00	
10	35,420	2.68	7.44	—	23,340	16,340	1.97	7.49	9.60	0.00	0.00	
11	33,220	2.35	7.43	—	20,510	15,930	1.64	7.48	9.50	0.00	0.00	
12	33,400	2.38	7.43	—	20,320	15,830	1.68	7.47	9.70	0.00	0.00	
13	32,720	2.43	7.40	—	20,360	15,110	1.66	7.47	10.00	0.00	0.00	
14	33,430	1.98	7.42	—	20,290	15,280	1.25	7.48	10.00	0.00	0.00	
15	33,240	2.13	7.42	—	20,300	15,450	1.28	7.44	10.10	0.00	0.00	
16	32,770	2.00	7.39	—	20,620	14,760	1.17	7.43	10.10	0.00	0.00	
17	33,440	2.43	7.42	—	21,310	14,990	1.51	7.48	10.60	0.00	0.00	
18	32,180	2.56	7.42	—	19,280	15,390	1.56	7.49	10.50	0.00	0.00	
19	31,640	2.62	7.42	—	19,280	14,810	1.67	7.49	10.30	0.00	0.00	
20	32,770	2.68	7.43	—	19,580	15,210	1.60	7.51	10.60	0.00	0.00	
21	32,710	2.08	7.40	—	19,330	15,090	1.25	7.48	10.80	0.00	0.00	
22	31,810	2.66	7.43	—	18,850	15,440	1.53	7.52	11.50	0.00	0.00	
23	32,130	3.12	7.39	—	19,690	15,350	1.95	7.50	11.10	0.00	0.00	
24	32,140	3.13	7.38	—	19,720	15,370	1.97	7.50	11.00	0.00	0.00	
25	31,640	3.14	7.40	—	19,250	15,540	1.99	7.48	10.70	0.00	0.00	
26	32,270	2.92	7.38	—	19,510	15,600	1.98	7.43	10.50	0.00	0.00	
27	33,850	2.78	7.40	—	20,750	15,640	1.44	7.48	10.70	0.00	0.00	
28	34,040	2.84	7.34	—	20,330	16,360	1.75	7.48	10.80	0.00	0.00	
29	30,360	2.77	7.33	—	18,970	13,860	1.80	7.43	10.60	0.00	0.00	
30	33,990	2.87	7.32	—	21,060	14,760	1.82	7.39	10.60	0.00	0.00	
合計	1,012,680			—	635,090	492,390				0.00	0.00	
最大	37,550	3.14	7.45	—	24,270	20,090	1.99	7.52	11.50	0.00	0.00	
最小	30,360	1.98	7.32	—	18,850	13,860	1.17	7.39	8.00	0.00	0.00	
平均	33,756	2.50	7.41	—	21,170	16,413	1.62	7.48	9.90	0.00	0.00	

初野浄水場 流量水質報告書

令和5年5月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7カ 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	31,450	2.86	7.32	—	20,350	14,420	1.74	7.43	11.30	0.00	0.00	
2	30,280	2.49	7.26	—	17,320	12,950	2.16	7.43	11.30	0.00	0.00	
3	31,400	2.64	7.29	—	19,120	15,180	1.60	7.43	11.30	0.00	0.00	
4	32,220	2.58	7.29	—	18,900	15,350	1.70	7.41	11.30	0.00	0.00	
5	30,970	2.46	7.27	—	18,780	14,420	1.61	7.40	11.40	0.00	0.00	
6	32,120	2.53	7.26	—	19,740	14,600	1.56	7.35	11.40	0.00	0.00	
7	31,350	2.52	7.21	—	19,830	14,670	1.53	7.36	11.20	0.00	0.00	
8	31,810	4.38	7.17	—	20,330	14,280	1.87	7.34	10.60	0.00	0.00	
9	31,280	3.37	7.26	—	19,000	14,750	2.06	7.37	11.50	0.00	0.00	
10	31,610	3.37	7.26	—	19,040	14,720	2.15	7.35	11.70	0.00	0.00	
11	31,530	3.63	7.22	—	18,380	15,170	2.39	7.34	12.00	0.00	0.00	
12	31,590	3.75	7.20	—	18,410	15,100	2.12	7.36	12.10	0.00	0.00	
13	33,710	3.29	7.22	—	21,170	14,770	2.37	7.34	12.30	0.00	0.00	
14	33,910	3.43	7.19	—	22,120	14,680	2.44	7.34	12.40	0.00	0.00	
15	33,570	3.57	7.18	—	21,640	14,400	2.61	7.31	12.20	0.00	0.00	
16	31,810	3.29	7.15	—	19,350	15,410	2.22	7.33	12.50	0.00	0.00	
17	31,570	3.28	7.18	—	18,360	15,080	2.26	7.30	12.50	0.00	0.00	
18	31,510	3.45	7.16	—	18,260	15,130	2.24	7.30	13.20	0.00	0.00	
19	33,870	3.46	7.14	—	19,510	16,440	2.30	7.29	13.20	0.00	0.00	
20	28,850	3.60	7.08	—	17,350	13,770	2.34	7.28	12.90	0.00	0.00	
21	31,540	3.54	7.12	—	19,880	15,650	2.34	7.24	13.00	0.00	0.00	
22	31,310	3.41	7.12	—	19,270	14,330	2.28	7.25	13.20	0.00	0.00	
23	31,380	3.42	7.13	—	18,670	15,080	2.25	7.26	13.10	0.00	0.00	
24	31,080	3.42	7.08	—	19,010	14,690	2.27	7.25	12.90	0.00	0.00	
25	31,920	2.62	7.12	—	19,100	15,350	1.65	7.27	13.10	0.00	0.00	
26	32,340	2.70	7.12	—	19,440	15,480	1.80	7.26	13.00	0.00	0.00	
27	36,230	3.32	7.11	—	23,510	17,720	2.31	7.20	13.10	0.00	0.00	
28	36,640	3.24	7.08	—	24,140	18,360	2.18	7.18	13.10	0.00	0.00	
29	36,520	3.23	7.06	—	25,160	17,170	2.19	7.17	13.00	0.00	0.00	
30	36,300	2.45	7.09	—	24,010	17,820	1.62	7.17	13.10	0.00	0.00	
31	35,210	2.38	7.05	—	21,830	18,870	1.53	7.20	13.20	0.00	0.00	
合計	1,006,880			—	620,980	475,810				0.00	0.00	
最大	36,640	4.38	7.32	—	25,160	18,870	2.61	7.43	13.20	0.00	0.00	
最小	28,850	2.38	7.05	—	17,320	12,950	1.53	7.17	10.60	0.00	0.00	
平均	32,480	3.15	7.17	—	20,032	15,349	2.05	7.31	12.33	0.00	0.00	

初野浄水場 流量水質報告書

令和5年6月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7.0 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	33,810	2.51	7.08	—	20,930	18,270	1.70	7.21	13.10	0.00	0.00	
2	36,670	2.57	7.07	—	23,200	19,860	1.81	7.16	13.20	0.00	0.00	
3	34,390	2.76	7.03	—	22,640	17,850	1.66	7.16	13.20	0.00	0.00	
4	36,020	2.92	7.07	—	23,600	19,270	1.78	7.21	13.60	0.00	0.00	
5	34,490	3.20	7.05	—	21,780	18,400	1.96	7.22	13.60	0.00	0.00	
6	35,500	3.73	7.03	—	22,440	18,860	2.46	7.15	13.60	0.00	0.00	
7	36,950	3.71	7.01	—	23,720	19,560	2.59	7.13	13.90	0.00	0.00	
8	36,050	3.75	7.03	—	23,220	19,100	2.65	7.14	13.90	0.00	0.00	
9	36,100	3.65	7.01	—	23,860	18,940	2.50	7.19	13.90	0.00	0.00	
10	37,810	4.39	7.02	—	25,920	19,430	3.26	7.15	14.10	0.00	0.00	
11	35,790	4.01	7.00	—	24,410	18,460	2.89	7.17	14.00	0.00	0.00	
12	36,000	3.91	6.96	—	25,070	18,040	2.84	7.10	14.00	0.00	0.00	
13	36,950	3.80	6.97	—	25,050	19,970	2.72	7.09	13.90	0.00	0.00	
14	36,170	3.81	6.98	—	24,000	19,610	2.73	7.08	14.00	0.00	0.00	
15	35,570	4.86	6.95	—	23,750	19,120	3.95	7.10	14.00	0.00	0.00	
16	36,180	3.37	6.94	—	24,080	19,230	3.31	7.09	14.10	0.00	0.00	
17	36,550	3.98	7.00	—	24,240	19,850	3.19	7.16	14.20	0.00	0.00	
18	37,220	5.61	6.97	—	24,070	19,880	3.79	7.11	14.50	0.00	0.00	
19	34,820	5.08	6.95	—	22,420	18,370	4.58	7.09	14.40	0.00	0.00	
20	35,470	5.27	6.97	—	22,810	19,460	4.27	7.11	14.50	0.00	0.00	
21	35,800	5.21	7.01	—	23,040	19,590	3.99	7.15	14.60	0.00	0.00	
22	36,320	5.30	6.98	—	23,400	19,850	3.90	7.13	14.50	0.00	0.00	
23	36,080	5.40	6.95	—	23,700	19,460	4.07	7.15	14.60	0.00	0.00	
24	36,180	5.18	6.97	—	24,260	19,750	4.16	7.11	14.70	0.00	0.00	
25	35,980	5.06	6.96	—	25,980	19,030	3.88	7.14	14.90	0.00	0.00	
26	35,310	4.85	6.95	—	21,330	18,680	3.65	7.09	14.80	0.00	0.00	
27	35,420	4.71	6.97	—	23,470	19,760	3.57	7.12	14.90	0.00	0.00	
28	37,080	4.66	6.95	—	23,470	20,480	3.16	7.11	15.00	0.00	0.00	
29	34,920	3.70	6.96	—	21,770	19,200	2.93	7.11	15.20	0.00	0.00	
30	35,390	3.70	6.96	—	21,610	19,820	2.80	7.09	15.20	0.00	0.00	
合計	1,076,990			—	703,240	577,150				0.00	0.00	
最大	37,810	5.61	7.08	—	25,980	20,480	4.58	7.22	15.20	0.00	0.00	
最小	33,810	2.51	6.94	—	20,930	17,850	1.66	7.08	13.10	0.00	0.00	
平均	35,900	4.16	6.99	—	23,441	19,238	3.09	7.13	14.20	0.00	0.00	

初野浄水場 流量水質報告書

令和5年7月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	添加 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	35,950	3.53	6.94	—	23,830	20,090	2.59	7.08	14.90	0.00	0.00	
2	36,610	3.50	6.95	—	24,180	19,710	2.59	7.11	15.10	0.00	0.00	
3	34,270	3.47	6.93	—	22,130	17,980	2.43	7.07	15.10	0.00	0.00	
4	37,140	3.40	6.90	—	23,570	20,600	2.51	7.08	15.10	0.00	0.00	
5	32,060	2.88	6.90	—	20,400	17,690	2.21	7.06	15.10	0.00	0.00	
6	37,960	3.26	6.92	—	24,830	19,770	2.55	7.09	15.20	0.00	0.00	
7	36,210	2.77	6.92	—	23,660	19,280	1.91	7.08	15.30	0.00	0.00	
8	37,400	2.82	6.91	—	23,800	20,290	1.99	7.05	15.40	0.00	0.00	
9	35,730	2.84	6.91	—	24,190	18,280	1.95	7.07	15.60	0.00	0.00	
10	35,600	2.92	6.91	—	23,740	18,150	2.06	7.08	15.70	0.00	0.00	
11	35,990	2.90	6.92	—	22,810	19,390	2.07	7.11	15.70	0.00	0.00	
12	36,500	2.32	6.93	—	23,120	19,840	2.07	7.07	15.70	0.00	0.00	
13	36,390	2.44	6.89	—	23,040	19,980	1.82	7.11	15.70	0.00	0.00	
14	35,670	2.56	6.93	—	22,590	19,200	1.87	7.11	15.70	0.00	0.00	
15	37,030	2.57	6.92	—	24,300	19,400	1.73	7.07	15.80	0.00	0.00	
16	36,630	2.49	6.94	—	24,770	19,410	1.79	7.11	16.00	0.00	0.00	
17	34,840	2.54	6.92	—	22,830	18,660	1.70	7.10	15.90	0.00	0.00	
18	35,640	2.53	6.90	—	22,610	19,360	1.69	7.09	15.90	0.00	0.00	
19	36,600	2.55	6.90	—	22,900	19,860	1.73	7.05	15.80	0.00	0.00	
20	35,430	2.51	6.89	—	21,540	19,070	1.66	7.08	16.10	0.00	0.00	
21	35,810	2.20	6.88	—	21,870	19,080	1.67	7.06	16.00	0.00	0.00	
22	35,150	2.12	6.91	—	23,370	18,630	1.64	7.06	16.20	0.00	0.00	
23	36,620	2.05	6.92	—	24,010	18,870	1.56	7.05	16.30	0.00	0.00	
24	34,750	2.07	6.91	—	22,530	18,120	1.55	7.08	16.30	0.00	0.00	
25	34,760	2.07	6.91	—	22,150	18,900	1.50	7.04	16.30	0.00	0.00	
26	36,040	2.13	6.89	—	22,270	19,550	1.46	7.03	16.30	0.00	0.00	
27	36,110	2.14	6.89	—	22,270	19,660	1.52	7.04	16.40	0.00	0.00	
28	35,140	2.20	6.90	—	22,150	19,130	1.49	7.03	16.30	0.00	0.00	
29	36,190	2.24	6.90	—	22,390	19,420	1.51	7.02	16.40	0.00	0.00	
30	35,650	2.36	6.89	—	23,280	18,490	1.57	7.03	16.40	0.00	0.00	
31	35,260	2.41	6.88	—	22,150	18,330	1.57	7.00	16.40	0.00	0.00	
合計	1,111,130			—	713,280	594,190				0.00	0.00	
最大	37,960	3.53	6.95	—	24,830	20,600	2.59	7.11	16.40	0.00	0.00	
最小	32,060	2.05	6.88	—	20,400	17,690	1.46	7.00	14.90	0.00	0.00	
平均	35,843	2.61	6.91	—	23,009	19,167	1.87	7.07	15.81	0.00	0.00	

初野浄水場 流量水質報告書

令和5年8月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7/20 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	37,980	2.38	6.87	—	24,450	20,030	1.58	6.98	16.30	0.00	0.00	
2	34,140	2.35	6.90	—	21,940	18,080	1.58	7.00	16.50	0.00	0.00	
3	35,490	2.40	6.90	—	22,690	18,700	1.59	7.02	16.50	0.00	0.00	
4	36,690	2.52	6.88	—	23,220	19,390	1.65	7.04	16.80	0.00	0.00	
5	35,580	2.53	6.89	—	22,560	18,810	1.67	7.05	16.90	0.00	0.00	
6	34,880	2.55	6.86	—	22,540	18,610	1.67	7.00	16.90	0.00	0.00	
7	35,580	2.65	6.85	—	22,430	18,780	1.63	7.03	16.90	0.00	0.00	
8	35,480	2.68	6.89	—	22,410	19,470	1.68	7.02	17.80	0.00	0.00	
9	35,560	2.56	6.90	—	22,430	19,100	1.67	7.03	18.10	0.00	0.00	
10	35,870	2.64	6.88	—	22,100	19,540	1.74	7.02	18.20	0.00	0.00	
11	35,710	2.56	6.88	—	22,510	18,560	1.67	7.02	18.20	0.00	0.00	
12	35,650	2.37	6.86	—	22,620	17,600	1.69	7.05	18.20	0.00	0.00	
13	36,800	2.99	6.88	—	24,600	17,540	2.27	7.05	17.00	0.00	0.00	
14	34,240	2.75	6.87	—	22,210	16,360	2.13	7.01	18.40	0.00	0.00	
15	35,590	2.78	6.87	—	23,140	17,570	2.29	6.99	18.50	0.00	0.00	
16	36,550	2.87	6.88	—	23,740	18,330	2.46	7.03	18.70	0.00	0.00	
17	36,480	3.03	6.87	—	23,880	19,380	2.36	7.00	18.90	0.00	0.00	
18	33,400	3.10	6.85	—	20,730	17,680	2.32	7.02	18.80	0.00	0.00	
19	36,270	3.11	6.84	—	22,800	19,190	2.34	6.99	18.90	0.00	0.00	
20	35,230	2.97	6.84	—	22,870	18,140	2.17	6.99	18.90	0.00	0.00	
21	35,430	2.78	6.86	—	23,190	18,030	2.10	7.01	19.00	0.00	0.00	
22	35,630	2.60	6.88	—	22,070	18,920	1.98	6.99	19.00	0.00	0.00	
23	36,490	2.42	6.86	—	23,570	19,350	1.86	7.01	19.10	0.00	0.00	
24	36,880	2.32	6.88	—	22,690	19,700	1.86	7.04	19.10	0.00	0.00	
25	33,420	2.29	6.86	—	20,640	18,210	1.81	7.02	19.00	0.00	0.00	
26	35,890	2.12	6.84	—	22,400	19,650	1.76	7.00	19.20	0.00	0.00	
27	35,610	1.98	6.84	—	23,080	18,500	1.72	7.02	19.20	0.00	0.00	
28	35,040	1.96	6.84	—	23,220	18,260	1.77	7.06	19.20	0.00	0.00	
29	35,060	2.01	6.82	—	22,550	19,190	1.80	7.00	19.40	0.00	0.00	
30	35,410	2.08	6.84	—	22,130	19,530	1.83	7.00	19.30	0.00	0.00	
31	36,070	2.65	6.83	—	22,740	19,790	1.86	7.01	19.20	0.00	0.00	
合計	1,104,100			—	704,150	579,990				0.00	0.00	
最大	37,980	3.11	6.90	—	24,600	20,030	2.46	7.06	19.40	0.00	0.00	
最小	33,400	1.96	6.82	—	20,640	16,360	1.58	6.98	16.30	0.00	0.00	
平均	35,616	2.55	6.86	—	22,715	18,709	1.89	7.02	18.26	0.00	0.00	

初野浄水場 流量水質報告書

令和5年9月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7次 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	34,960	2.02	6.81	—	21,770	19,450	1.39	6.99	18.30	0.00	0.00	
2	36,990	2.11	6.80	—	22,760	21,020	1.21	7.00	18.30	0.00	0.00	
3	35,630	2.23	6.80	—	23,190	19,720	1.25	7.02	18.50	0.00	0.00	
4	34,050	2.25	6.80	—	21,930	18,430	1.34	7.00	18.50	0.00	0.00	
5	36,270	2.56	6.80	—	23,440	20,070	1.75	6.97	18.70	0.00	0.00	
6	35,360	2.77	6.80	—	22,760	19,370	1.72	6.95	18.70	0.00	0.00	
7	35,080	3.70	6.79	—	22,610	18,880	2.53	7.00	18.60	0.00	0.00	
8	36,020	4.72	6.74	—	23,170	19,690	3.57	6.89	18.60	0.00	0.00	
9	34,970	8.80	6.69	—	22,880	19,050	5.47	6.81	18.90	0.00	0.00	
10	35,460	8.70	6.70	—	23,790	19,000	7.30	6.84	18.70	0.00	0.00	
11	35,310	8.30	6.69	—	23,410	19,130	7.73	6.83	19.20	0.00	0.00	
12	35,960	7.25	6.74	—	23,400	20,070	6.75	6.88	19.20	0.00	0.00	
13	35,010	6.05	6.74	—	21,740	19,530	5.31	6.91	19.20	0.00	0.00	
14	36,190	5.51	6.76	—	22,610	20,310	4.79	6.93	19.30	0.00	0.00	
15	35,960	5.06	6.77	—	23,130	20,090	4.08	6.97	19.30	0.00	0.00	
16	34,450	5.02	6.71	—	22,130	19,080	4.36	6.90	19.40	0.00	0.00	
17	35,700	4.56	6.76	—	23,340	19,260	3.89	6.91	19.50	0.00	0.00	
18	36,330	4.11	6.76	—	23,820	19,210	3.59	6.93	19.60	0.00	0.00	
19	35,120	3.87	6.78	—	22,420	18,990	3.26	6.97	19.30	0.00	0.00	
20	36,680	3.68	6.78	—	23,480	20,490	3.17	6.97	19.20	0.00	0.00	
21	36,090	2.97	6.78	—	22,930	19,970	2.39	6.98	19.20	0.00	0.00	
22	35,560	2.93	6.78	—	23,100	19,960	2.41	6.98	19.40	0.00	0.00	
23	35,370	2.96	6.76	—	22,440	19,160	2.34	6.97	19.30	0.00	0.00	
24	35,060	3.03	6.76	—	23,010	18,440	2.42	6.98	19.30	0.00	0.00	
25	36,880	3.01	6.75	—	23,950	19,330	2.51	6.96	19.40	0.00	0.00	
26	35,500	3.03	6.75	—	23,500	19,000	2.60	6.94	19.40	0.00	0.00	
27	34,930	2.94	6.75	—	21,190	19,540	2.53	6.90	19.40	0.00	0.00	
28	35,750	2.81	6.73	—	23,000	19,120	2.50	6.90	19.30	0.00	0.00	
29	35,470	2.65	6.73	—	22,430	19,800	2.33	6.95	19.40	0.00	0.00	
30	36,370	2.69	6.78	—	22,870	19,970	2.25	6.94	19.30	0.00	0.00	
合計	1,068,480			—	686,200	585,130				0.00	0.00	
最大	36,990	8.80	6.81	—	23,950	21,020	7.73	7.02	19.60	0.00	0.00	
最小	34,050	2.02	6.69	—	21,190	18,430	1.21	6.81	18.30	0.00	0.00	
平均	35,616	4.08	6.76	—	22,873	19,504	3.29	6.94	19.08	0.00	0.00	

初野浄水場 流量水質報告書

令和5年10月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	36,290	2.73	6.73	—	23,790	18,910	2.34	6.91	19.30	0.00	0.00	
2	34,990	2.54	6.75	—	23,370	18,380	2.28	6.94	19.30	0.00	0.00	
3	34,410	2.47	6.82	—	21,970	18,610	2.11	7.00	19.30	0.00	0.00	
4	37,270	2.50	6.75	—	23,170	19,410	2.11	7.00	19.20	0.00	0.00	
5	34,550	2.54	6.74	—	22,000	17,790	2.16	6.95	19.10	0.00	0.00	
6	36,560	2.70	6.77	—	23,530	19,850	2.23	6.99	19.00	0.00	0.00	
7	35,220	3.02	6.80	—	22,700	18,870	2.53	7.01	18.70	0.00	0.00	
8	35,400	2.82	6.82	—	22,900	18,630	2.43	7.03	18.50	0.00	0.00	
9	35,760	2.85	6.80	—	23,730	18,560	2.44	7.02	18.30	0.00	0.00	
10	34,920	2.76	6.80	—	23,070	18,040	2.38	6.98	18.40	0.00	0.00	
11	35,900	2.69	6.79	—	22,940	19,010	2.04	6.97	18.40	0.00	0.00	
12	34,950	2.67	6.80	—	21,720	18,620	1.76	7.02	18.20	0.00	0.00	
13	36,230	2.89	6.82	—	22,800	19,100	1.86	7.05	18.20	0.00	0.00	
14	38,350	2.61	6.82	—	24,100	20,350	1.84	7.07	18.30	0.00	0.00	
15	32,830	2.52	6.81	—	21,390	17,070	1.89	7.05	18.00	0.00	0.00	
16	36,050	2.52	6.82	—	23,860	18,730	1.82	7.06	18.00	0.00	0.00	
17	35,180	2.53	6.83	—	22,480	18,850	1.77	7.08	17.80	0.00	0.00	
18	36,470	2.61	6.87	—	23,310	19,730	1.86	7.07	17.80	0.00	0.00	
19	34,760	2.73	6.86	—	21,990	18,600	2.08	7.06	17.70	0.00	0.00	
20	34,960	2.57	6.88	—	23,000	18,910	2.01	7.08	17.70	0.00	0.00	
21	33,920	1.99	6.85	—	21,910	18,840	1.47	7.09	17.60	0.00	0.00	
22	33,980	2.09	6.88	—	22,320	18,170	1.48	7.11	17.30	0.00	0.00	
23	33,960	2.22	6.89	—	21,910	18,320	1.64	7.12	17.20	0.00	0.00	
24	34,290	2.55	6.87	—	22,340	19,060	1.86	7.09	17.10	0.00	0.00	
25	34,130	2.53	6.87	—	22,360	18,760	3.07	7.10	17.00	0.00	0.00	
26	35,750	2.58	6.90	—	23,710	19,670	1.98	7.12	17.00	0.00	0.00	
27	34,410	2.56	6.91	—	23,110	18,870	1.92	7.10	16.90	0.00	0.00	
28	33,250	3.03	6.89	—	21,810	18,370	2.15	7.10	16.80	0.00	0.00	
29	33,840	2.65	6.87	—	23,090	18,570	2.23	7.09	16.80	0.00	0.00	
30	36,030	2.61	6.90	—	24,240	18,930	2.19	7.11	16.70	0.00	0.00	
31	35,070	2.80	6.90	—	23,580	18,680	2.20	7.10	16.60	0.00	0.00	
合計	1,089,680			—	708,200	582,260				0.00	0.00	
最大	38,350	3.03	6.91	—	24,240	20,350	3.07	7.12	19.30	0.00	0.00	
最小	32,830	1.99	6.73	—	21,390	17,070	1.47	6.91	16.60	0.00	0.00	
平均	35,151	2.61	6.83	—	22,845	18,783	2.07	7.05	17.94	0.00	0.00	

初野浄水場 流量水質報告書

令和5年11月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7カ 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	34,450	2.81	6.93	—	23,030	18,360	2.40	7.02	16.50	0.00	0.00	
2	34,770	2.88	6.89	—	23,220	18,580	2.42	7.02	16.50	0.00	0.00	
3	35,090	2.99	6.94	—	23,440	18,910	2.50	7.03	16.50	0.00	0.00	
4	35,210	2.92	6.95	—	23,850	18,780	2.49	7.03	16.40	0.00	0.00	
5	35,210	2.95	6.90	—	23,820	18,580	2.04	7.07	16.40	0.00	0.00	
6	35,730	3.18	6.91	—	25,030	18,900	2.70	7.07	16.40	0.00	0.00	
7	33,590	2.64	6.92	—	22,830	18,720	2.24	7.06	16.40	0.00	0.00	
8	35,850	2.98	6.92	—	24,310	19,820	2.43	6.92	16.30	0.00	0.00	
9	34,740	3.21	6.98	—	22,250	18,970	2.48	7.14	16.00	0.00	0.00	
10	34,910	3.31	6.92	—	22,650	18,530	2.83	7.09	15.90	0.00	0.00	
11	34,900	3.50	6.92	—	22,650	18,530	2.94	7.11	15.90	0.00	0.00	
12	34,890	3.59	6.99	—	24,600	18,320	3.03	7.10	15.40	0.00	0.00	
13	35,790	3.69	6.99	—	24,640	18,680	3.22	7.07	15.10	0.00	0.00	
14	33,530	3.46	6.98	—	22,420	18,190	3.23	7.14	14.80	0.00	0.00	
15	35,100	4.56	6.98	—	23,170	19,290	3.81	7.15	14.70	0.00	0.00	
16	36,210	4.45	6.97	—	23,900	19,750	4.27	7.14	14.50	0.00	0.00	
17	33,370	4.50	6.97	—	22,130	18,300	4.30	7.12	14.40	0.00	0.00	
18	35,680	4.31	6.99	—	23,960	19,600	3.79	7.14	14.30	0.00	0.00	
19	34,120	4.41	7.00	—	22,880	18,320	4.03	7.14	14.20	0.00	0.00	
20	34,580	5.09	6.98	—	23,320	18,610	4.75	7.11	14.00	0.00	0.00	
21	35,130	5.25	7.01	—	23,710	19,400	4.62	7.12	13.80	0.00	0.00	
22	34,430	6.13	7.01	—	22,780	18,600	5.25	7.10	13.60	0.00	0.00	
23	39,010	5.64	7.03	—	24,090	21,290	5.07	7.11	13.70	0.00	0.00	
24	31,920	5.61	7.00	—	19,460	17,460	4.86	7.10	13.60	0.00	0.00	
25	34,260	5.42	7.03	—	23,240	19,220	4.60	7.13	13.40	0.00	0.00	
26	37,730	5.86	7.05	—	25,670	20,320	4.71	7.13	13.10	0.00	0.00	
27	32,430	6.38	7.04	—	21,810	17,410	6.01	7.11	12.90	0.00	0.00	
28	33,740	6.19	7.03	—	22,090	18,510	5.72	7.12	12.80	0.00	0.00	
29	36,040	5.62	7.05	—	24,110	20,150	5.22	7.15	12.80	0.00	0.00	
30	33,870	5.82	7.03	—	22,940	18,590	5.31	7.13	12.50	0.00	0.00	
合計	1,046,280			—	698,000	566,690				0.00	0.00	
最大	39,010	6.38	7.05	—	25,670	21,290	6.01	7.15	16.50	0.00	0.00	
最小	31,920	2.64	6.89	—	19,460	17,410	2.04	6.92	12.50	0.00	0.00	
平均	34,876	4.31	6.98	—	23,267	18,890	3.78	7.10	14.76	0.00	0.00	

初野浄水場 流量水質報告書

令和5年12月分

項目 目	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7効) 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	35,830	5.65	7.04	—	23,660	19,590	5.18	7.12	12.30	0.00	0.00	
2	34,620	5.87	7.05	—	23,000	19,510	5.42	7.15	12.20	0.00	0.00	
3	34,180	6.33	7.04	—	22,450	18,970	5.83	7.14	12.00	0.00	0.00	
4	34,610	5.81	7.05	—	23,440	19,270	5.25	7.14	11.90	0.00	0.00	
5	34,800	10.24	6.89	—	23,150	19,670	10.63	7.01	11.20	0.00	0.00	
6	36,560	11.17	6.86	—	24,750	20,920	10.62	6.95	11.20	0.00	0.00	
7	33,380	5.74	7.03	—	22,710	18,760	5.82	7.09	11.50	0.00	0.00	
8	36,090	5.80	7.04	—	23,490	21,000	5.26	7.15	11.60	0.00	0.00	
9	33,420	5.47	7.09	—	21,350	18,930	5.26	7.17	11.40	0.00	0.00	
10	34,900	5.38	7.08	—	23,470	19,590	5.01	7.14	11.30	0.00	0.00	
11	35,360	4.82	7.07	—	23,960	19,660	4.62	7.15	11.40	0.00	0.00	
12	34,040	5.09	7.02	—	22,450	19,550	4.93	7.15	11.20	0.00	0.00	
13	34,440	4.17	7.07	—	23,070	19,450	4.10	7.16	11.10	0.00	0.00	
14	35,500	4.33	7.11	—	23,390	20,650	4.13	7.21	10.90	0.00	0.00	
15	34,940	4.60	7.12	—	23,250	20,100	4.81	7.22	10.80	0.00	0.00	
16	33,970	5.13	7.09	—	22,740	19,420	5.56	7.18	10.70	0.00	0.00	
17	33,980	4.12	7.11	—	22,740	19,420	4.22	7.22	10.70	0.00	0.00	
18	34,990	4.07	7.13	—	23,870	19,890	4.17	7.23	10.30	0.00	0.00	
19	36,160	3.75	7.13	—	24,030	20,740	4.08	7.24	10.20	0.00	0.00	
20	33,930	5.22	7.13	—	22,380	19,660	5.92	7.23	10.00	0.00	0.00	
21	33,980	4.46	7.11	—	22,210	19,760	5.45	7.22	9.70	0.00	0.00	
22	34,880	4.06	7.13	—	22,660	20,120	5.17	7.21	9.60	0.00	0.00	
23	36,020	3.88	7.15	—	23,100	20,880	4.52	7.24	9.50	0.00	0.00	
24	33,820	2.12	7.15	—	22,760	19,700	4.86	7.21	9.30	0.00	0.00	
25	34,180	1.47	7.11	—	23,000	19,580	6.55	7.20	9.10	0.00	0.00	
26	35,130	7.65	7.10	—	23,210	20,770	6.03	7.21	9.00	0.00	0.00	
27	35,400	5.50	7.12	—	23,430	20,880	4.48	7.21	9.00	0.00	0.00	
28	33,510	6.12	7.14	—	22,400	19,730	4.97	7.22	8.70	0.00	0.00	
29	34,820	6.67	7.12	—	23,050	20,010	5.02	7.23	8.70	0.00	0.00	
30	34,680	6.70	7.14	—	22,780	19,660	4.91	7.21	8.60	0.00	0.00	
31	34,730	7.31	7.09	—	22,580	19,960	5.71	7.19	8.70	0.00	0.00	
合計	1,076,850			—	714,530	615,800				0.00	0.00	
最大	36,560	11.17	7.15	—	24,750	21,000	10.63	7.24	12.30	0.00	0.00	
最小	33,380	1.47	6.86	—	21,350	18,760	4.08	6.95	8.60	0.00	0.00	
平均	34,737	5.44	7.08	—	23,049	19,865	5.44	7.17	10.45	0.00	0.00	

初野浄水場 流量水質報告書

令和6年1月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	7カ 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	34,580	5.84	7.08	—	22,760	20,030	5.23	7.17	8.60	0.00	0.00	
2	34,750	5.57	7.16	—	23,590	19,960	4.24	7.22	8.40	0.00	0.00	
3	34,760	5.85	7.12	—	23,870	20,110	4.30	7.21	8.50	0.00	0.00	
4	34,800	6.65	7.05	—	23,940	20,040	4.91	7.16	8.40	0.00	0.00	
5	35,080	4.78	7.14	—	24,030	20,480	4.02	7.18	8.30	0.00	0.00	
6	33,970	5.25	7.11	—	22,730	19,810	3.97	7.17	8.30	0.00	0.00	
7	34,540	6.04	7.05	—	23,920	19,780	5.06	7.11	8.20	0.00	0.00	
8	34,830	5.34	7.11	—	23,910	19,910	4.26	7.16	8.00	0.00	0.00	
9	34,550	6.94	7.11	—	22,680	19,660	5.80	7.17	7.90	0.00	0.00	
10	36,080	11.30	7.07	—	23,950	20,550	9.20	7.16	7.90	0.00	0.00	
11	35,680	7.76	7.09	—	23,430	20,330	6.45	7.18	7.70	0.00	0.00	
12	35,750	7.74	7.13	—	23,230	20,610	6.41	7.21	7.60	0.00	0.00	
13	33,690	6.65	7.11	—	21,920	19,810	5.51	7.19	7.50	0.00	0.00	
14	34,600	8.50	7.14	—	23,170	19,890	7.23	7.18	7.40	0.00	0.00	
15	34,690	9.29	7.15	—	23,180	19,980	7.42	7.22	7.30	0.00	0.00	
16	35,150	10.90	7.15	—	22,680	20,320	9.46	7.20	7.00	0.00	0.00	
17	35,510	9.24	7.20	—	23,330	20,860	7.68	7.22	6.90	0.00	0.00	
18	33,870	9.26	7.23	—	21,910	20,060	7.86	7.25	6.90	0.00	0.00	
19	34,210	9.77	7.22	—	22,310	19,860	8.28	7.24	6.90	0.00	0.00	
20	35,140	8.03	7.24	—	23,340	20,630	6.71	7.25	6.80	0.00	0.00	
21	34,890	7.76	7.22	—	23,320	20,330	6.59	7.27	6.70	0.00	0.00	
22	35,310	11.91	7.18	—	24,080	19,980	13.01	7.26	6.80	0.00	0.00	
23	35,030	10.41	7.16	—	23,120	20,540	9.08	7.19	6.70	0.00	0.00	
24	32,870	8.59	7.17	—	21,420	19,170	6.82	7.24	6.70	0.00	0.00	
25	35,690	11.16	7.19	—	22,950	20,550	10.13	7.25	6.40	0.00	0.00	
26	35,020	12.15	7.21	—	23,080	20,770	10.65	7.27	6.20	0.00	0.00	
27	33,810	13.27	7.22	—	22,220	19,840	11.87	7.27	6.30	0.00	0.00	
28	34,880	14.14	7.24	—	23,150	19,710	12.47	7.27	6.10	0.00	0.00	
29	34,720	14.22	7.25	—	23,220	19,580	12.76	7.29	6.10	0.00	0.00	
30	34,560	14.57	7.26	—	22,610	20,140	12.68	7.29	6.20	0.00	0.00	
31	35,160	14.38	7.21	—	22,700	20,490	12.89	7.30	6.20	0.00	0.00	
合計	1,078,170			—	715,750	623,780				0.00	0.00	
最大	36,080	14.57	7.26	—	24,080	20,860	13.01	7.30	8.60	0.00	0.00	
最小	32,870	4.78	7.05	—	21,420	19,170	3.97	7.11	6.10	0.00	0.00	
平均	34,780	9.14	7.16	—	23,089	20,122	7.84	7.22	7.25	0.00	0.00	

初野浄水場 流量水質報告書

令和6年2月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	34,020	15.41	7.18	—	22,030	19,760	13.41	7.28	6.20	0.00	0.00	
2	35,880	15.49	7.15	—	23,310	20,890	13.93	7.29	6.00	0.00	0.00	
3	33,550	14.72	7.16	—	21,780	19,740	12.57	7.26	5.90	0.00	0.00	
4	34,670	13.66	7.20	—	23,400	19,540	11.88	7.27	5.80	0.00	0.00	
5	34,230	13.27	7.18	—	22,650	19,260	11.07	7.28	5.80	0.00	0.00	
6	34,390	13.05	7.16	—	22,660	19,910	11.12	7.29	5.70	0.00	0.00	
7	36,280	12.16	7.22	—	23,760	20,660	13.61	7.30	5.60	0.00	0.00	
8	33,710	11.60	7.45	—	21,390	19,450	9.20	7.31	5.70	0.00	0.00	
9	36,480	10.72	7.47	—	22,140	19,610	15.48	7.63	5.60	0.00	0.00	
10	32,180	8.85	7.47	—	21,200	18,210	8.48	7.65	5.60	0.00	0.00	
11	35,070	8.33	7.46	—	23,360	19,860	7.72	7.64	5.60	0.00	0.00	
12	34,530	7.99	7.48	—	23,100	19,480	7.03	7.65	5.60	0.00	0.00	
13	34,660	7.53	7.49	—	22,640	20,040	6.65	7.66	5.60	0.00	0.00	
14	35,150	7.06	7.47	—	22,670	20,690	6.38	7.65	5.80	0.00	0.00	
15	34,790	7.02	7.47	—	22,450	20,460	6.43	7.63	6.00	0.00	0.00	
16	34,120	6.00	7.46	—	22,250	20,310	5.51	7.66	6.10	0.00	0.00	
17	37,350	6.73	7.48	—	25,630	19,980	6.63	7.80	5.90	0.00	0.00	
18	38,460	6.89	7.45	—	27,130	19,490	6.26	7.68	6.00	0.00	0.00	
19	38,320	5.90	7.45	—	26,930	19,560	10.60	7.64	6.20	0.00	0.00	
20	35,410	4.91	7.45	—	23,330	20,820	4.05	7.65	6.90	0.00	0.00	
21	34,110	5.16	7.46	—	22,220	20,110	4.00	7.66	6.90	0.00	0.00	
22	33,740	4.62	7.44	—	22,370	19,300	3.79	7.64	6.10	0.00	0.00	
23	35,410	4.46	7.43	—	23,110	20,170	3.40	7.64	6.20	0.00	0.00	
24	35,420	4.23	7.44	—	23,530	20,030	3.36	7.64	6.00	0.00	0.00	
25	34,320	4.18	7.48	—	22,790	19,350	3.22	7.66	6.00	0.00	0.00	
26	34,570	4.21	7.45	—	23,060	19,250	3.36	7.64	6.10	0.00	0.00	
27	34,530	4.21	7.45	—	22,530	20,090	3.04	7.67	6.00	0.00	0.00	
28	34,720	5.27	7.45	—	22,730	20,140	4.23	7.65	5.90	0.00	0.00	
29	34,770	5.22	7.47	—	22,290	20,380	4.16	7.67	6.00	0.00	0.00	
合計	1,014,840			—	668,440	576,540				0.00	0.00	
最大	38,460	15.49	7.49	—	27,130	20,890	15.48	7.80	6.90	0.00	0.00	
最小	32,180	4.18	7.15	—	21,200	18,210	3.04	7.26	5.60	0.00	0.00	
平均	33,796	8.24	7.39	—	22,281	19,178	7.61	7.55	5.96	0.00	0.00	

初野浄水場 流量水質報告書

令和6年3月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	PH	了効 度		配水量 (m3/日)	濁度 (ppm)	PH	水温 (°C)	PAC	苛性 ソーダ	
1	34,640	5.68	7.48	—	22,600	20,200	4.54	7.68	6.00	0.00	0.00	
2	34,610	5.32	7.49	—	22,870	20,480	3.90	7.69	6.00	0.00	0.00	
3	34,560	5.04	7.49	—	22,600	20,000	3.72	7.67	6.00	0.00	0.00	
4	36,080	4.76	7.50	—	23,410	21,050	3.40	7.69	6.20	0.00	0.00	
5	33,260	4.65	7.51	—	21,330	19,610	3.13	7.69	6.10	0.00	0.00	
6	34,080	5.31	7.47	—	22,150	19,840	4.09	7.67	5.90	0.00	0.00	
7	35,870	4.80	7.47	—	23,030	20,790	4.15	7.66	5.80	0.00	0.00	
8	34,200	5.79	7.47	—	21,910	19,770	4.35	7.67	5.70	0.00	0.00	
9	34,750	5.82	7.48	—	23,300	19,820	4.32	7.66	5.70	0.00	0.00	
10	34,960	4.76	7.50	—	23,250	20,020	3.82	7.67	5.70	0.00	0.00	
11	34,910	4.68	7.49	—	22,640	19,800	3.70	7.68	5.80	0.00	0.00	
12	34,660	4.32	7.52	—	22,170	19,890	3.21	7.68	6.00	0.00	0.00	
13	35,690	4.45	7.50	—	23,170	20,350	3.48	7.66	5.90	0.00	0.00	
14	36,880	4.95	7.53	—	23,790	21,550	3.67	7.69	6.10	0.00	0.00	
15	32,850	4.76	7.53	—	21,000	19,240	3.70	7.69	6.20	0.00	0.00	
16	34,770	6.41	7.54	—	22,540	20,810	3.65	7.68	6.50	0.00	0.00	
17	35,040	6.40	7.54	—	22,970	19,710	4.78	7.68	6.50	0.00	0.00	
18	34,540	5.43	7.54	—	22,930	19,720	4.56	7.70	6.60	0.00	0.00	
19	35,350	6.93	7.53	—	23,050	20,600	5.76	7.69	6.50	0.00	0.00	
20	34,670	6.58	7.55	—	22,840	20,070	5.53	7.70	6.50	0.00	0.00	
21	35,350	5.97	7.55	—	23,220	20,090	4.68	7.71	6.40	0.00	0.00	
22	34,830	6.38	7.58	—	22,820	20,410	5.03	7.71	6.50	0.00	0.00	
23	34,230	6.25	7.58	—	22,710	19,640	5.13	7.71	6.40	0.00	0.00	
24	34,670	6.13	7.56	—	23,220	19,560	5.23	7.69	6.50	0.00	0.00	
25	34,700	5.89	7.55	—	22,690	19,580	5.64	7.68	6.60	0.00	0.00	
26	34,930	3.99	7.58	—	22,710	20,240	3.88	7.68	6.70	0.00	0.00	
27	35,150	6.54	7.56	—	23,370	20,230	7.67	7.66	6.70	0.00	0.00	
28	34,590	4.34	7.57	—	22,280	20,020	4.26	7.68	7.00	0.00	0.00	
29	35,210	4.02	7.53	—	22,560	19,770	3.52	7.66	7.00	0.00	0.00	
30	33,530	5.21	7.53	—	22,550	19,030	6.85	7.63	7.60	0.00	0.00	
31	34,730	4.37	7.56	—	22,730	19,670	3.77	7.67	8.10	0.00	0.00	
合計	1,078,290			—	704,410	621,560				0.00	0.00	
最大	36,880	6.93	7.58	—	23,790	21,550	7.67	7.71	8.10	0.00	0.00	
最小	32,850	3.99	7.47	—	21,000	19,030	3.13	7.63	5.70	0.00	0.00	
平均	34,784	5.35	7.53	—	22,723	20,050	4.42	7.68	6.36	0.00	0.00	